

# Compliance Document

No. D 124661 0017 Rev. 00

**Holder of Certificate:** **Zhejiang Inventronics New Energy Technology Co., Ltd.**

West Section 2nd Floor, South Building  
Building 1, No.88, Huancheng South Road  
Tonglu Economic Development Zone  
Tonglu County  
311500 Hangzhou City, Zhejiang Province  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Converter  
(Hybrid inverter)**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290243022901

**Date,** 2024-03-19



( Billy Qiu )

# Compliance Document

No. D 124661 0017 Rev. 00

**Model(s):** HHB-05K000CRLV

## Parameters:

PV terminal	
Vmax. PV	580 Vd.c.
MPPT voltage range	125~550 Vd.c.
Max. continuous PV input current	13/13 Ad.c.
Isc PV	14/14 Ad.c.
Max. continuous PV input power	6000 W
Battery terminal parameter	
Battery type	Li-ion
Voltage range	40-58 Vd.c.
Rated voltage	48 Vd.c.
Maximum charge/discharge current	70/75 Ad.c.
Maximum charge/discharge power	3680/3680 W
Grid terminal parameter	
Rated voltage	230 Va.c.
Rated frequency	50 Hz
Rated input current	16 Aa.c.
Maximum continuous input current	16.8 Aa.c.
Maximum continuous input power	3680 W
Rated output current	16 Aa.c.
Maximum continuous output current	16.8 Aa.c.
Power factor (Cos phi), adjustable	0.8 inductive(under-excited) to 0.8 capacitive(over-excited)
Maximum continuous output power	3680 W
Backup load terminal parameter	
Rated voltage	230 Va.c.
Rated frequency	50 Hz
Rated output current	16 Aa.c.
Maximum continuous output current	16.8 Aa.c.
Maximum continuous output power	3680 W
General parameter	
Protective class	Class I
Overvoltage category	II(DC side), III(AC side)

**Tested  
according to:**

EN 50549-1:2019 (with Austrian national deviation of TOR  
Erzeuger Type A Version 1.0:2019)